

PREVENTIV PERMBLEDHES

Objekti: Rikonstruksioni i Pavionit Kemba Diabetike,
Spitali Universitar i Traumes

TIRANE

I	EMERYTIMI I PUNIMEVE	Vlera
A	PUNIME NDERTIMI	24764573.2
B	INSTALIME ELEKTRIKE	9853944.2
C	INSTALIME HIDRONIKE	15,865,153
	Shuma	50,483,670
	Fondi rezerve 5%	2,524,184
	Shuma	53,007,854
	TVSH ja 20 %	10,601,571
	Shuma I	63,609,425
II	PAISJE DHE MAKINERI	3,741,188
	Shuma II	3,741,188
	TOTALI (I+II)	67,350,613

Shoqeria "GD PLAN" sh.p.k

Administrator

Ing. Sandjon Kodhelaj



PREVENTIV ZBATIMI
Objekti: Rikonstruksioni i Pavionit Kemba Diabetike, Spitali Universitar i Traumes

Nr. Analize	Pershkrimi I zerit te punes A. PUNIME NDERTIMI	Njesia	Totali	Çmimi	Vlera
	1. Punime prishje				
2.426	Prishje mur tulle pa pastrim + nxjereje mbeturinave	m3	21	626	13146
A/p 1	Prishje shtrese mbrojtëse me lluster cimento 1:2 t = 20 mm + zbrirjen e mbeturinave	m2	715	102	72930
A/p 2	Prishje shtrese me pllaka + nxjerja jashte e mbeturinave	m2	1080	235.3	254124
A/p 3	C'montim vetrata pa demtuar paturat dhe davancalin + transportin e tyre ne vendin qe do te caktoje supervizori	m2	215	191	41065
An 4	Hegje dyerve , pa l dentuar ato dhe paturat , dorzimi I tyre ne vendin ku do te caktoje investitori, me proces verbal.	m2	170	331	56270
An 5	Prishje suvatimi ne mure tulle H deri 4 m, me krahe	m2	5100	198	1009800
An 6	Hegje e pajisjeve elektrike dhe dorezimi i tyre te punedhënesi + heqja e linjave te kondicionimit	d/pune	10	1942	19420
2.37/3a	Transport mbeturina ndertimi, me auto deri ne piken e c aktuar nga investitori	m3	290	255	73950
	Shuma 1	leke			1540705
	2. Punime murature				
2.64/2	Mur me tulle plotë ne lartësi deri 3m me llaç perzier M 25	m3	218	17728	3864704
	Shuma 2	leke			3864704
	3. Punime Hekur Betoni				
2.119/1	Ndërtim arkitar b/a mbi dyer,c-16/20,h-4 m	m3	6.6	15974	105428.4
2.166	F V hekur betoni periodik Ø 6 - 10 mm	ton	0.02549	113157	2884.37193
2.167	F V hekur betoni periodik Ø > 10 mm	ton	0.20281	103498	20990.42938
	Shuma 3	leke			129303.2013
	4. Punime H/Izolimi e Catie				
2.198	Hidroizolim me emulsion bitumi dhe 3 shtrese k katrama	m2	620	1624	1006880
2.200	Shtrese lluster cimento 1:2, t = 20 mm	m2	1240	343	425320
2.196/c	Hidroizolim me material 2 komponent mapëy ,2 duar me rrjete ne dysheme dhe deri ne 30 cm ne muret perimetral te wc	m2	765	1368	1046520
	Shuma 4	leke			2478720

	5. Punime shtresash						
2.264	Shtrese Niveluese llac cimento 4 cm	m2	1150	332	381800		
2.326	Veshje me pallke majolike (nyje higienosantitare deri ne lartesine e tavanit)	m2	460	2133	981180		
2.267/b	Shtrese me pllaka grez importi 40 x 40 cm	m2	950	2446	2323700		
2.324/b	Plintuse grez importi, h = 10 cm	m1	830	325	269750		
	Shuma 5	leke			3956430		
	6. Punime Tavani e suvatimi						
2.297/b	Tavan me kartonxhes (gips anti lageshtires, jeshil) dopjo	m2	950	2132	2025400		
2.310	Suva brenda mur tulle h=4m me krah, llac perzier M 25	m2	4200	674	2830800		
	Shuma 6	leke			4856200		
	7. Punime dyer dritare						
2.386/2	Dyer te blinduara importi. (salle e operacionit)	m2	22	42990	945780		
2.388/1	V F dyer te brendeshme tamburate te rimesuara	m2	95	14279	1356505		
2.383/1	F V dyer te brendeshme druri importi cilesi e l-re.	m2	66	21441	1415106		
2.375/a	Dritare d/alumini dyfish xham.	m2	240	10951	2628240		
	Sshuma 7	leke			6345631		
	8. Punime bojatisje						
2.328	Patinim muri allçi (stuko)	m2	2670	248	662160		
2.330	Patinim tavani allçi (stuko)	m2	1100	387	425700		
2.404	Boje hidroplastike ne mjediset e brendshme, ne tavanet me ngjyre te bardhe	m2	2470	174	429780		
2.404	Boje antibakteriale biologjikisht e paster ne tavane hidroplastike cilesia I	m2	90	431	38790		
2.403	Boje vaji mbi siperfaqe te patinuar	m2	270	135	36450		
	Shuma 8	leke			1592880		
	Shuma A				24764573.2		
	B. INSTALIMET ELEKTRIKE						
	I. Ndricuesit						
2. a-137	F.V. Ndricuesa 4x18W 60x60cm	cope	178	3963	705414		
2. a-136	F.V. Ndricuesa luminishent, FL1x60w, IP 65 PAR, tualet	cope	34	2600	88400		
2. a-139	Ndricues evakuimi me llampe 1x11w,IP40 me shenje EXIT	cope	9	4409	39681		
2. a-139	Ndricues evakuimi me llampe 1x11w,IP40	cope	8	4409	35272		
2.485/3	F.V Çeles I polar 220V 10A "Ticino"	cope	120	443	53160		
2.483	F.V Çelesa e priza 10 A	cope	230	467	107410		
2.487/e	F.V kuti suport pllaket 2 modular Ticino	cope	390	236	92040		

480/2	F.V tub plastmasi Ø 18 ~ 21 mm	ml	4850	120	582000
2.487	F.V Kutiderivacioni plastike	cope	85	121	10285
2.481/1	F.V perçjelles PV-500 Ø 1.5 mm2	ml	1560	32	49920
2.481/2	F.V perçjelles PV-500 Ø 2.5 mm2	ml	4380	49	214620
An 18	F.V. Kabell bakri me izolim dhe veshje PVCm ;K.Z. FG7-OR ; S=3x2.5 mm2	ml	4750	150	712500
Shuma 1		leke			2690702
2.Instalimet elektrike te fugise dhe traseja e kablllove					
2.485/d	F.V priza shuko "Geviss" universal	cope	245	510	124950
2.487	F.V Kutiderivacioni plastike	cope	42	121	5082
An 19	F.V. Kanaline metalike e birezuar. S = 300 x 60mm	ml	115	2625	301875
2. a-121	F.V. Kanaline metalike e birezuar. S = 150 x 60 mm	ml	65	1427	92755
Shuma 2		leke			524662
3. Paneli elektrik					
An 27	FV suport siguresash 3P+N, modulare me siguresa 2A	cope	1	2931	2931
An 28	FV shkarkuesi mbitemsoni 3P+N, tip SPD, T1+T2 / 12.5 kA komplet me shogertesin	cope	1	27782	27782
2. a-120	Llampe sinjalizimi 220V;1.2w	cope	3	598	1794
An 29	F.V. Automat magneto-termik. In=200A/4P kl. C ; Icc=16 KA, Un=400V	cope	1	28546	28546
An 30	F.V. Automat magneto-termik diferencial , In=25A/4P kl. C ; Icc=6 KA, Un=400V ; 0.03A	cope	4	11979	47916
2. a-106	F.V. Automat magneto-termik diferencial , In=40A/4P kl. C ; Icc=6 KA, Un=400V ; 0.03A	cope	8	17829	142632
An 31	F.V. Kit zbarra modulare CU 4P/100A, per tu montuar ne shine DIN	cope	6	4333	25998
2.490/1a	F.V. Automat magneto-termik, tip C40N, In=10A/2P, kl. C ; Icc=10 KA, Un=220V	cope	65	1006	65390
2.490/1b	F.V. Automat magneto-termik, tip C40N, In=16A/2P kl. C ; Icc=6 KA, Un=220V	cope	34	1279	43486
Shuma 3		leke			386475
4. Sistemi I Data & Telefonise					
An. E-1.1	F.V RACK Kompiuterik 19" 42U, tip metalik, me dere xhami te armuar, me celes, drejtues kablllosh, modul ushqimi dhe ventiliimi me 6 priza shuko 230V, 16A me tokezim	cope	1	133,000.0	133,000.0

An. E-1.2	F.V Centrali Telefonise Analog me 6 hyrje 32 dalje	cope	1	138,000.0	138,000.0
An. E-1.3	F.V Telefona Analoge Me Display	cope	16	4,140.0	66,240.0
An. E-1.4	F.V Patchpanel data 24Porta FTP CAT.6	cope	1	13,110.0	13,110.0
An. E-1.5	F.V Patchpanel data 24Porta UTP CAT.5e (telefonja)	cope	1	7,590.0	7,590.0
An. E-1.6	F.V Gigabit Smart Switch 24 Porta (data)	cope	1	106,260.0	106,260.0
An. E-1.7	F.V Priza data RJ45 FTP CAT. 6 me aksesore montimi	cope	22	1,656.0	36,432.0
An. E-1.8	F.V Priza telefonie RJ45 UTP CAT. 6 me aksesore montimi	cope	16	1,242.0	19,872.0
An. E-1.9	F.V Kabull rrejt LAN FTP CAT.6	ml	950	82.8	78,660.0
An. E-1.10	F.V Kabull telefonie UTP CAT.6	ml	720	48.3	34,776.0
An. E-1.11	F.V Tub plastmasi Ø 22 ~ 26 mm	ml	930	162.0	150,660.0
	Shuma 4	leke			784,600.0
	5. Sistemi I Vezhgimit CCTV				
An. E-2.1	F.V NVR 16 kanale 200Mbps Bit Rate Input Max (up to 32-ch IP video), 4 SATA Interfaces, alarm I/O: 16/4, 1.5U case,19	cope	1	220,000.0	220,000.0
An. E-2.2	F.V Kamera te jashtme – 5MPx, Resolution, Low illumination, lens: 4mm, 3D DNR & DWDR & BLC, System Compatibility: ONVIF, PSIA, CGI, ISAPI IP66 rating, Image Sensor: 1/3" Progressive Scan CMOS IR range: up to 50m	cope	2	42,500.0	85,000.0
An. E-2.3	F.V Kamera te brendshme – 5MPx, 30 metra IR Exir Dome Dome Outdoor IR 30 metra, 2048x1536:12.5fps(P)/15fps(N), 2.8mm/F2.0 lens (4mm, 6mm optional)	cope	10	37,300.0	373,000.0
An. E-2.4	F.V HDD 4TB 3.5 inch. Kapaciteti 4000GB, Sata. Purple HDD (i dizenuar vecanerisht per Security, per te punuar 7dite ne Jave, 24 ore. Si edhe me jete gjatesi me te gjate se nje HDD i zakonshem kompjuteri ndaj ofron me shume garanci ne sherbim)	cope	1	33,120.0	33,120.0
An. E-2.5	F.V Switch i menaxhueshem me 16 Porta Gigabit POE	cope	1	193,200.0	193,200.0
An. E-2.6	F.V Aksesore montimi te pershtatshem per kamera te jashtme dhe te brendshme	cope	12	2,070.0	24,840.0
An. E-2.7	F.V Kabull rrejt LAN FTP CAT. 6 per linjat e kamerave	ml	220	82.8	18,216.0
An. E-2.8	F.V Tub plastmasi Ø 22 ~ 26 mm	ml	140	42.5	5,950.0
An. E-2.9	F.V Kutiderivacioni plastike, me izolim PVC me kapak, PT-2-4, IP55 montuar jashte murit	cope	12	276.0	3,312.0
An. E-2.10	F.V Programim, testim dhe komisionim i sistemit te vezhgimit CCTV	komplet	1	50,000.0	50,000.0
	Shuma 5	leke			1,006,638.0

B. INSTALIMET ELEKTRIKE						
	1. Ndricuesit					
Analize	F. V. Ndricues katorr panel LED, tip inkaso, 60x60cm, 40W, 3350lm, IP40, 4000K, me difuzor opal, i kompletuar se bashku me transformator	cope	146	7927	1157371.2	
Analize	F. V. Ndricues katorr panel LED, tip inkaso, 60x60cm, 39W, 3850lm, IP54, 4000K, me difuzor mikropriematik, i kompletuar se bashku me transformator	cope	35	17224	602823	
Analize	F. V. Ndricues rrethor LED spot inkaso, 20W, IP44, i kompletuar se bashku me transformator per vendosje brenda ne tavan gipsi	cope	37	4521	167288	
Analize	F. V. Ndricues rrethor LED plafonier, 25W, IP20, i kompletuar se bashku me transformator per vendosje jashte murit	cope	4	5328	21310	
2. a-139	F. V. Ndricues evakuimi me llampe 1x11w, IP40 me shenje EXIT	cope	16	4409	70544	
2. a-139	F. V. Ndricues evakuimi me llampe 1x11w, IP40	cope	20	4409	88180	
2.485/2	F. V. Çeles 1 polar 220V 10A "Gevis"	cope	175	443	77525	
2.483	F. V. Çelesa e priza 10 A	cope	230	467	107410	
2.487/a	F. V. Kuti suport pllaket 3 modular	cope	305	277	84485	
2.487/b	F. V. Kuti suport pllaket 4 modular	cope	35	364	12740	
480/2	F. V. Tub plasmasi Ø 18 ~ 21 mm	ml	4850	120	582000	
2.487	F. V. Kutiderivacioni plastike	cope	85	121	10285	
2.481/1	F. V. Percjelles PV-500 Ø 1.5 mm2	ml	2600	32	83200	
2.481/2	F. V. Percjelles PV-500 Ø 2.5 mm2	ml	6500	49	318500	
Analize	F. V. Kabell bakri me izolim dhe veshje PVCm ;K.Z. FG7-OR ; S=3x2.5 mm2	ml	3190	150	478500	
Analize	F. V. Kabell bakri me izolim dhe veshje PVCm ;K.Z. FG7-OR ; S=3x4 mm2	ml	460	190	87400	
Analize	F. V. Kabell bakri me izolim dhe veshje PVCm ;K.Z. FG7-OR ; S=4x16 mm2	ml	35	1671	58485	
Analize	F. V. Kabell bakri me izolim dhe veshje PVCm ;K.Z. FG7-OR ; S=5x25 mm2	ml	22	2178	47916	
Analize	F. V. Kabell bakri me izolim dhe veshje PVCm ;K.Z. FG7-OR ; S=5x6 mm2	ml	120	466	55920	
	Shuma 1	leke			3862161	
2.485/d	2.Instalimet elektrike te fuqise dhe traseja e kablllove					
	F. V Priza shuko "Gevis" universal	cope	245	510	124950	

2.487	F.V. Kuiderivacioni plastike	cope	160	121	19360
Analize	F.V. Kanaline metalike e birezuar. S = 300 x 60mm	ml	115	2625	301875
2. a-121	F.V. Kanaline metalike e birezuar. S = 150 x 60 mm	ml	110	1427	156970
	Shuma 2	leke			603155
	3. Sistemi i Paneleve dhe Kuadrove Elektrike				
	3.1 Kuadri elektrik kati per dhe				
Analize	F.V. Kuadri kryesor metalik me dim 2000/600/250 mm, IK08 me porte me xham, komp.me kit zbara 250A per montim jash/murri dhe aksesoret si me poshte: - 7 Pjastra ballore 4 module (200mm lartesi) per vendosjen e automateve - 2 Pjastra ballore 4 module (200mm lartesi) te mbyllura per vendosjen e klemave - 1 Pjaster ballore per montimin e automatit 4P, 200A 4 module h=200mm - 1 Pjaster fundore per montimin e automatit 4P, 200A 4 module h=200mm - 9 Shina modulare DIN me gjatesi standarte 600 mm per tu montuar ne panel - Klementa modulare per seksion percjellesi 2.5mm2 cope 150	cope	1	96344	96344
Analize	F.V. Suport + automat magneto-termik, 3-fazor 400V, 32A, 3P+N, 10kA, per mbrojtjen e shkartkuesit te mbtensionit 32A,	cope	1	2931	2931
Analize	FV shkartkuesi mbtensionioni 3P+N, tip SPD, T1+T2 / 12.5 kA komplet me shogernesin	cope	1	27782	27782
Analize	F.V. Analizator digital i parametrave te rrejetit elektrik per monitorimin ne kohe reale te gjithë parametrave te rrejetit elektrik 400V, 3P+N, (V, A, kW, kVA, f, cosφ, kWh, kVAh), te instaluar ne hyrje te cdo paneli elektrik	cope	1	24010	24010
2. a-120	Llampe sinjalizimi 220V;1.2w	cope	3	598	1794
Analize	F.V. Automat magneto-termik modulare MCC, In=250A/4P; Icc=25 kA, Un=400V	cope	1	28546	28546
Analize	F.V. Automat magneto-termik modulare MCCB, In=200A/4P, Icc=25 kA, Un=400V	cope	2	25998	51996
Analize	F.V. Automat magneto-termik modulare MCCB, In=160A/4P, Icc=25 kA, Un=400V	cope	1	23449	23449
Analize	F.V. Automat magneto-termik, In=80A/4P, Icc=10 kA, Un=400V	cope	1	18438	18438
2. a-106	F.V. Automat magneto-termik, In=40A/4P, Icc=10 kA, Un=400V	cope	2	17829	35658

2. a-105	Automat termo-elektro magnetik, 4P, 380V, 40A	cope	1	2234	2234
2. a-107	F.V Automat magneto-termik 380V, 63A, 4P	cope	1	27221	27221
Analize	F.V Automat magneto-termik diferencial , In=25A/4P kl. C ; Icc=6 KA, Un=400V ; 0.03A	cope	3	11979	35937
2. a-106	F.V Automat magneto-termik diferencial , In=40A/4P kl. C ; Icc=6 KA, Un=400V ; 0.03A	cope	4	17829	71316
2. a-101	Çeles automat termo-elektro magnetik 2P, 20A, 220V	cope	2	1373	2746
Analize	F.V Kit zbarra modulare CU 4P/400A, per tu montuar ne shine DIN	cope	6	4333	25998
2.490/1a	F.V Automat magneto-termik, tip C40N, In=10A/2P, kl. C ; Icc=6 kA, Un=220V	cope	20	1006	20120
2.490/1b	F.V Automat magneto-termik, tip C40N, In=16A/2P kl. C ; Icc=6 kA, Un=220V	cope	20	1279	25580
	Shuma 3.1	leke			522100
	3.2 Kuadri elektrik kati +1				
2.490/h	F.V Kasete Plastike KE me 54 modular (vende)	cope	1	7779	7779
Analize	F.V Suport siguresash 3P+N, modulare me siguresa 2A	cope	1	2931	2931
Analize	F.V shkarkuesi mbtensiononi 3P+N, tip SPD, T1+T2 / 12.5 kA komplet me shogertesin	cope	1	27782	27782
2. a-120	Llampe sinjalizimi 220V ; 1.2w	cope	3	598	1794
2. a-107	F.V Automat magneto-termik 380V, 63A, 4P	cope	1	27221	27221
Analize	F.V Automat magneto-termik diferencial , In=25A/4P kl. C ; Icc=6 KA, Un=400V ; 0.03A	cope	2	11979	23958
2. a-106	F.V Automat magneto-termik diferencial , In=40A/4P kl. C ; Icc=6 KA, Un=400V ; 0.03A	cope	2	17829	35658
2.490/1a	F.V Automat magneto-termik, tip C40N, In=10A/2P, kl. C ; Icc=10 KA, Un=220V	cope	21	1006	21126
2.490/1b	F.V Automat magneto-termik, tip C40N, In=16A/2P kl. C ; Icc=6 KA, Un=220V	cope	16	1279	20464
	Shuma 3.2	leke			168713
	3.3 Kuadri elektrik kati +2				
2.490/f	F.V Kasete Metalike 36 module	cope	1	3289	3289
Analize	F.V suport siguresash 3P+N, modulare me siguresa 2A	cope	1	2931	2931
Analize	FV shkarkuesi mbtensiononi 3P+N, tip SPD, T1+T2 / 12.5 kA komplet me shogertesin	cope	1	27782	27782

2. a-120	Llampe sinjalizimi 220V;1.2w	cope	3	598	1794
Analize	F.V Automat magneto-termik diferencial , In=25A/4P kl. C ; Icc=16 KA, Un=400V ; 0.03A	cope	1	16053	16053
2. a-106	F.V Automat magneto-termik diferencial , In=10A/4P kl. C ; Icc=10 KA, Un=400V ; 0.03A	cope	1	8960	8960
2.490/1a	F.V Automat magneto-termik, tip C40N, In=10A/2P, kl. C ; Icc=10 KA, Un=220V	cope	2	1006	2012
2.490/1b	F.V Automat magneto-termik, tip C40N, In=16A/2P kl. C ; Icc=6 KA, Un=220V	cope	3	1279	3837
	Shuma 3.3	Ieke			66658
	3.4 Kuadri elektrik i korridorit te salles operatorore				
2. a-118	F.V Kasete Metalike 36 module	cope	1	25553	25553
Analize	F.V Suport siguresash 3P+N, module me siguresa 2A	cope	1	2931	2931
Analize	F.V shkarkuesi mbtensioni 3P+N, tip SPD, T1+T2 / 12.5 kA komplet me shoqeruesin	cope	1	27782	27782
2. a-120	Llampe sinjalizimi 220V;1.2w	cope	3	598	1794
Analize	F.V Automat magneto-termik diferencial , In=25A/4P kl. C ; Icc=6 KA, Un=400V ; 0.03A	cope	2	11979	23958
2. a-106	F.V Automat magneto-termik diferencial , In=40A/4P kl. C ; Icc=6 KA, Un=400V ; 0.03A	cope	1	17829	17829
2.490/1a	F.V Automat magneto-termik, tip C40N, In=10A/2P, kl. C ; Icc=10 KA, Un=220V	cope	6	1006	6036
2.490/1b	F.V Automat magneto-termik, tip C40N, In=16A/2P kl. C ; Icc=6 KA, Un=220V	cope	6	1279	7674
	Shuma 3.4	Ieke			113557
	Shuma 3 (3.1+3.2+3.3+3.4)	Ieke			757471
	4. Sistemi i Detektimit te Zjarrit				
Analize	F.V Central i alarmit te zjarrit, tip inteligjent, i adresueshem, me regjistrim ngjarjesh, modul komunikimi, grafik karte, me porte kompjuterike, i programueshem, me bateri me 72 ore pavarresi	cope	1	560000	560000
Analize	F.V Detektore tymi multi sensitiv, inteligjent te adresueshem, me modul komunikimi	cope	59	7500	442500
Analize	F.V Detektore nxehesie multi sensitiv inteligjent te adresueshem, me modul komunikimi	cope	3	7890	23670

Analize	F.V Sirena alarmi zjarri, me ndricues me llambe vezulluese, per vendosje ne ambient te brendshem, tip inteligjent te adresuesheme, me intensitet 120dB.	cope	4	9800	39200
Analize	F.V Sirena alarmi zjarri, me ndricues me llambe vezulluese, per vendosje ne ambient te jashtem, tip inteligjent te adresuesheme, me intensitet 120dB.	cope	1	12600	12600
Analize	F.V Pulsant manual alarmi zjarri me thyerje xhami, tip 1469, IP-65	cope	8	8100	64800
Analize	F.V Kablo alarmi zjarri JE-H(ST), S=2x1.5mm2 per loop-in e detektoreve	cope	630	98.0	61740
Analize	F.V Kablo alarmi zjarri FTG10(O)M1, me S=2x1.5mm2, per loop-in te sirenave, me rezistence ndaj zjarrit deri 3ore	cope	220	254.0	55880
Analize	F.V Lampa sinjalizuese (qe vendosen nen tavanin e gipsit)	cope	22	1,750.0	38500
480/3	F.V Tub plastmasi Ø 22 ~ 26 mm	ml	260	162	42120
	Shuma 4	leke			1341010
	5. Sistemi i Data, Telefonise dhe TV				
Analize	F.V RACK Kompiuterik 19" 42U, tip metalik, me dere xhami te armuar, me celes, drejtues kabllosh, modul ushqimi dhe ventiliimi me 6 priza shuko 230V, 16A me tokenzim	cope	1	133000	133000
Analize	F.V Centrali Telefonise Analog me 6 hyrje 42 dalje	cope	1	138000	138000
Analize	F.V Telefona Analoge Me Display	cope	16	4140	66240
Analize	F.V Patchpanel data 24Porta FTP CAT.6	cope	2	13110	26220
Analize	F.V Patchpanel data 24Porta UTP CAT.5e (telefonja)	cope	2	7590	15180
Analize	F.V Gigabit Smart Switch 24 Porta (data)	cope	2	106260	212520
Analize	F.V Priza data RJ45 FTP CAT. 6 me aksesore montimi	cope	39	1656	64584
Analize	F.V Priza telefonie RJ45 UTP CAT. 6 me aksesore montimi	cope	33	1242	40986
Analizë	F.V. Kuti plastike per priza 3-module, suport , kapak & tapa	cope	54	420	22680
Analize	F.V Kabull rrethi LAN FTP CAT.6	ml	1,200	82.8	99360
Analize	F.V Kabull telefonie UTP CAT.6	ml	1,050	48.3	50715
480/3	F.V Tub plastmasi Ø 22 ~ 26 mm	ml	930	162	150660
Analizë	F.V. Priza televizive RJ14 per kablo coaxial RG 59/U, 75 ohm	cope	32	590	18880
Analize	F.V. Kablo koaksial RG59/U per lidhjen e TV	ml	700	58	40600
Analize	F.V. Tub Antene D25-30 MT 4 SP.1 2EL	cope	1	2369	2369.4
Analize	F.V. Derivator sinjalit televiziv DE-2	cope	3	747	2241.6
Analize	F.V. Derivator I sinjalit televiziv DE-4	cope	13	900	11700
Analize	F.V. Derivator I sinjalit televiziv DE-6	cope	6	1184	7102.8

Analize	F.V. ANTENE me 6 ELEMENT .VHF"5-12" UHF"21-69" F.Y	cope	1	15000	15000
Analize	F.V. CENTRALINO TV 1IN III+DAB+UHF 33DB	cope	1	5683	5682.8
Analize	F.V. Multi switch I sinjalit TV (4IN 24 OUT)+(2IN SAT)	cope	1	18000	18000
Analize	F.V. Amplifikator antene e sinjalit televiziv 24 abonente	cope	1	9930	9930
Analize	F.V. Rezistenca fundore per mbylljen e linjave ne switch	cope	1	734	733.5
	Shuma 5	leke			887145
	6. Sistemi i Vezhgimit CCTV				
	F.V NVR - Network Video Recorder 24-channel 4K, 1.5U, 24-port PoE 4K H.265, 19", per montim ne rack H.265+ and Smart H.264+ Video Compression • Maximum 320 Mbps Incoming Bandwidth • Up to 12 MP Resolution for Preview and Playback • Support for IPC and UPnP Protocols • 24 PoE Ports • Customized Live View Layout with Support for Panoramic Displays • Intelligent Video System • 3D Intelligent Positioning with PTZ Cameras	• Smart			
Analize		cope	1	360,000.0	360000
Analize	F.V Kamera te jashtme -IP66, Resolution:12MPx (4K), ULTRA HD, Day/Night Functionality, Lens Size: 1.83mm Fixed Lens. Max. FPS and Resolution:20fps at 4K (12MP); Sensor Size:1/2.3"; Sensor Type:CMOS; Technology:Network (IP); Camera Style:Box; Key Features:Wide Dynamic Range (WDR), ONVIF, SD Card Storage Support; Vandal Proof:No; SD Card Support:Yes; Weatherproof:yes; Product Type:Cameras; Warranty:3-year Manufacturer Warranty; Compression:H.264, MJPEG IR range: up to 50m Lens	cope	2	87,970.0	175940
Analize	F.V Kamera te brendshme - Resolution:12MPx (4K), ULTRA HD, Day/Night Functionality, Lens Size: 1.83mm Fixed Lens. Max. FPS and Resolution:20fps at 4K (12MP); Sensor Size:1/2.3"; Sensor Type:CMOS; Technology:Network (IP); Camera Style:Box; Key Features:Wide Dynamic Range (WDR), ONVIF, SD Card Storage Support; Vandal Proof:No; SD Card Support:Yes; Weatherproof:No; Manufacturer:Samsung; Product Type:Cameras; Warranty:3-year Manufacturer Warranty; Compression:H.264, MJPEG IR range: up to 30m Lens	cope	14	78,356.0	1096984

Analize	F.V HDD KRYESOR - 4TB 3,5 inch. Kapaciteti 4000GB, Sata. Purple HDD (i dizenuar vecanerisht per Security, per te punuar 7dite ne Jave, 24 ore. Si edhe me jetegjatesi me te gjate se nje HDD i zakonshem kompjuteri ndaj ofron me shume garanci ne sherbim)	cope	1	33,120.0	33120
Analize	F.V HDD - Rezerve (Back Up) - 4TB 3,5 inch. Kapaciteti 4000GB, Sata. Purple HDD (i dizenuar vecanerisht per Security, per te punuar 7dite ne Jave, 24 ore. Si edhe me jetegjatesi me te gjate se nje HDD i zakonshem kompjuteri ndaj ofron me shume garanci ne sherbim)	cope	1	33,120.0	33120
Analize	F.V Switch i menaxhueshem me 24 Porta RJ45 Gigabit POE, per sistemin e vezhgjimit te kamerave	cope	1	193,200.0	193200
Analize	F.V Aksesore montimi te pershtatshem per kamera te jashtme dhe te brendshme	cope	12	2,070.0	24840
Analize	F.V Kabull rrejtje LAN FTP CAT. 6 per linjat e kamerave	ml	220	82.8	18216
Analize	F.V Tub plastmasi Ø 22 ~ 26 mm	ml	140	42.5	5950
Analize	F.V Kutiderivacioni plastike, me izolim PVC me kapak, PT-2-4, IP55 montuar jashte murit	cope	12	276.0	3312
Analize	F.V Programim, testim dhe komisionim i sistemit te vezhgjimit CCTV	komplet	1	50,000.0	50000
Analize	F.V Monitor vezhgjimi per monitorimin dhe vezhgjimin e kamerave, Smart, LED, 32inch	cope	1	42,920.0	42920
	Shuma 6	leke			2037602
	7. Sistemi i Tokkezimit dhe Mbrojtjes Atmosferike				
Analize	F.V Shtiza metalike per prifjen e goditjeve atmosferike h=1.5m	cope	19	1606	30514
Analize	F.V. Shufte FeZn dim D=10mm	ml	290	184	53360
Analize	F.V Morseta bashkuese T-1 & kryq universale	cope	250	102	25500
Analize	F.V Morseta bashkuese bakri "C" per kapjen e 2 percjellesave S=35mm2	cope	55	344	18920
Analize	F.V Shkeputes per matje te tokkezimit & kuti PT-5;Ip-65 , me shenje "toke"	cope	10	2969	29690
Analize	F.V Tulla betoni 150x100x70mm per izolimin e nderteses nga shifra e hekurit	cope	260	89	23140
Analize	F.V Izolator per montimin e shufres gjate zbritjes nga taraca	cope	100	359	35900
2.a-73	F.V Elektroda tokkezimi, profili zingato e bakerizuar , L=1.5m	cope	16	1315	21040
2.a-93	F.V Percjelles tokkezimi bakri , Cu, S=35mm2 i zhveshur	ml	205	770	157850
	Shuma 7	leke			365400
	Shuma B				9853944.2

C. INSTALIME HIDRONIKE									
1. Cmontimi i instalimeve dhe paisjeve mekanike									
An 32	Cmontim i lavamaneve dhe grumbullimi I tyre brenda kantierit	cope	23	764	17572				
An 33	Cmontim i WC dhe grumbullimi I tyre brenda kantierit	cope	23	841	19343				
An 34	Cmontim i pjates se dushit dhe grumbullimi brenda kantierit	cope	16	1070	17120				
An 8	Cmontim i instalimeve te shkarkimit te ujerave te zezra dhe grumbullimi I tyre brenda kantierit	dite	4	1942	7768				
An 8	Cmontim i instalimeve te furnizimit me uje dhe grumbullimi I tyre brenda kantierit	dite	3	1942	5826				
Shuma 1		leke			67629				
2. Furnizimi me uje nga rrjeti									
Analyze 1.1	F.V Rakorderi PE - HD (bryla, ti, reduksion, etj)	kompl	1	21,842.0	21,842				
Analyze 1.2	F.V Valvol nderperese me sfere DN 50 (2")	cope	2	3,166.0	6,332				
Analyze 1.3	F.V Fiter uji me rrjete DN 50, Pn 6 bar"	cope	1	2,156.0	2,156				
Analyze 1.4	F.V Mates uji DN 50, Pn 6 bar	cope	1	23,097.0	23,097				
Analyze 1.5	F.V Valvol moskthimi DN 50, Pn 6 bar"	cope	1	6,041.0	6,041				
Analyze 1.6	F.V Reduktor presioni DN 50, Pn 6 bar	cope	1	7,392.0	7,392				
Shuma 2		leke			66,860				
3. Sistemi i shperndarjes se ujit sanitar									
Analyze 1.7	F.V Tubo PE -Xa, DN 40 (Ø50 X 5.9) mm	ml	35	796.0	27,860				
Analyze 1.8	F.V Tubo PE -Xa, DN 32 (Ø40 X 5.5) mm	ml	67	655.0	43,885				
Analyze 1.9	F.V Tubo PE -Xa, DN 25 (Ø32 X 4.4) mm	ml	80	448.0	35,840				
Analyze 1.10	F.V Tubo PE -Xa, DN 20 (Ø25 X 3.5) mm	ml	115	377.0	43,355				
Analyze 1.11	F.V Tubo PE -Xa, DN 15 (Ø20 X 2.8) mm,	ml	140	304.0	42,560				
Analyze 1.12	F.V Tubo PE -Xa, DN 12 (Ø16 X 2.2) mm	ml	156	233.0	36,348				
Analyze 1.13	F.V Rakorderi PE -Xa (bryla, ti, reduksion, etj)	kompl	1	22,720.0	22,720				
Analyze 1.14	F.V Termoizolim armoflex per tubo PE-Xa, DN40 (Ø50 X 5.9) mm	ml	35	230.0	8,050				
Analyze 1.15	F.V Termoizolim armoflex per tubo PE-Xa, DN32 (Ø40 X 5.5) mm	ml	67	152.0	10,184				
Analyze 1.16	F.V Termoizolim armoflex per tubo PE-Xa, DN25 (Ø32 X 4.4) mm	ml	80	132.0	10,560				

Analize 1.17	F.V Termozizolim armoflex per tubo PE-Xa, DN20 (Ø25 X 2.8) mm	ml	115	115.0	13,225
Analize 1.18	F.V Termozizolim armoflex per tubo PE-Xa, DN15 (Ø20 X 2.8) mm	ml	140	100.0	14,000
Analize 1.19	F.V Termozizolim armoflex per tubo PE-Xa, DN12 (Ø16 X 2.2) mm	ml	156	155.0	24,180
Analize 1.20	F.V Minivalvula nderperese per pajisjet sanitare Ø 1/2"	cope	78	776.0	60,528
	Shuma 3	leke			393,295
	4. Lidhjet hidraulike me piken e furnizimit me uje				
Analize 1.21	F.V Tubo geliku zingato dhe rakorderi Ø 2"	kg	130	258.0	33,540
Analize 1.22	F.V Tubo geliku zingato dhe rakorderi Ø 1½"	kg	165	258.0	42,570
Analize 1.23	F.V Tubo geliku zingato dhe rakorderi Ø 1¼"	kg	90	258.0	23,220
Analize 1.24	F.V Valvol nderperese me sfere DN 50 (2")	cope	1	2,438.0	2,438
Analize 1.25	F.V Valvol nderperese me sfere DN 32 (1¼")	cope	1	1,286.0	1,286
Analize 1.26	F.V Valvol nderperese me sfere DN 25 (1")	cope	2	967.0	1,934
Analize 1.27	F.V Valvol nderperese me sfere DN 20 (¾")	cope	26	675.0	17,550
	Shuma 4	leke			122,538
	5. Shkarkimi i jashtem i ujrave te zeza				
2.521	Tub kanalizimi pvc Ø 140 mm	ml	85	1,380.0	117,300
2.52	Tub kanalizimi pvc Ø 110 mm	ml	230	1194	274,620
2.519	Tub kanalizimi pvc Ø 90 mm	ml	165	952.0	157,080
2.515	F.V VENTILATOR 110 m³/h, Fe - 20 W - per tualetet	cope	20	10282	205,640
	Shuma 5	leke			754,640
	6. Impianti i mbrojtjes nga zjarri				
2.493/1	F.V Tub celik Ø 1 1/2" + Rakorderi	kg	460	339	155,940
An 36	Eletroda saldimi	kg	12	1661	19,932
2.494/5	F.V Valvol nderperese me sfere DN 50 (2") - 40 (1½")	cope	10	2,438.0	24,380
An 37	F.V Tabela drejtim dalje	cope	9	881	7,929
An 38	F.V Tabela hidranti	cope	5	1058	5,290
An 37	F.V Tabela zbritje shkallësh	cope	3	881	2,643
An 38	F.V Tabela buton alarmi	cope	5	1053	5,265
An 38	F.V Tabele fikse zjarri me shkume	cope	7	1053	7,371
	Shuma 6	leke			228,750
	7. Impianti Kondicionimit				
An. M-1.1	Tub bakri (1/4") Ø 6.35 mm	ml	160	488.0	78,080
An. M-1.2	Tub bakri (3/8") Ø 9.52 mm	ml	150	521.0	78,150

An. M-1.3	Tub bakri (1/2") Ø 12.70 mm	ml	150	539.0	80850
2.494/a	Tub bakri (5/8") Ø 15.88 mm	ml	130	850.0	110500
2.494/b	Tub bakri (3/4") Ø 19.05 mm	ml	120	1,012.0	121440
2.494/c	Tub bakri (7/8") Ø 22.22 mm	ml	70	1,114.0	77980
2.494/d	Tub bakri (1-1/8") Ø28.58 mm	ml	50	1,314.0	65700
2.494/e	Tub bakri (1-3/8") Ø34.92 mm	ml	40	2,177.0	87080
An. M-1.9	Tub bakri (1-5/8") Ø41.28 mm	ml	25	3,030.0	75750
An. M-1.10	F.V Armaflex per tubo bakri Ø 6.35 mm	ml	160	189.0	30,240
An. M-1.11	F.V Armaflex per tubo bakri Ø 9.52 mm	ml	150	208.0	31,200
An. M-1.12	F.V Armaflex per tubo bakri Ø 12.7 mm	ml	150	227.0	34,050
An. M-1.13	F.V Armaflex per tubo bakri Ø 15.88 mm	ml	130	246.0	31,980
An. M-1.14	F.V Armaflex per tubo bakri Ø 19.05 mm	ml	120	276.0	33,120
An. 2.535/a	F.V Armaflex per tubo bakri Ø 22.22 mm	ml	70	127.0	8,890
An. 2.535/b	F.V Armaflex per tubo bakri Ø 28.58 mm	ml	50	127.0	6,350
An. 2.535/c	F.V Armaflex per tubo bakri Ø 24.92 mm	ml	40	163.0	6,520
An. M-1.18	F.V Armaflex per tubo bakri Ø41.28 mm	ml	25	362.0	9,050
An. M-1.19	F.V Degezime "Y" per lidhjen e pajisjeve me terminalin kryesor	cope	11	9,552.0	105,072
An. M-1.19/1	F.V Shpendares 6-8 dalje per lidhjen e pajisjeve terminalin kryesor	cope	4	19900	79600
An. M-1.20	F.V Mbushja e sistemit me gas ftohës	kg	36	2,275.0	81,900
2.491/c	F.V Tuba e rakorderi PE d=32mm,	ml	415	217.0	90,055
An. M-1.22	F.V Mbushja e sistemit hidronik me 20 % glikol, ne menyre qe te mos ngrije ne periudhen e dimrit kur temperaturat zbresin ne 0°C.	lit	55	341.0	18,755
An. M-1.23	F.V Llamarinë e galvanizuar per prodhimine e kanaleve te ajrit me trashësi nga (0.6mm - 1.20), e kompletuar me gjithë filaxha dhe te gjitha rakorderite e nevojshem per prodhimin dhe montimin e kanaleve te ajrit.	kg	4,555	320.0	1,457,600
An. M-1.24	F.V Termoizolues per tubacione kondicionimi	m²	95	614.0	58,330
An. M-1.25	F.V Grila Ventilimi 500 m³/h	cope	19	3,256.0	61,864
An. M-1.26	F.V Grila riqarkullimit te ajrit kondicionuar 45°+F+M, (60 /80 x 40 cm)	cope	2	13217	26434
An. M-1.27	F.V Kondicioner VRF Tipi Mural, kapaciteti ne ftohje / ngrohje 2.2 / 2.8 kW, prurja e ajrit mesatare Vaj.nom=490 m³/h, lidhjet Gaz / Leng - Ø 12.7 mm / Ø6.35 mm, I kompletuar me te gjithë elemente e nevojshem per montim, termostat ambienti, kabull komunikimi me pajisjen e jashtme si dhe te gjithë aksesoret e nevojshem.	cope	16	81,762.0	1,308,192

An. M-1.28	F. V Kondicioner VRF Tipi Mural, kapaciteti ne ftohje / ngrohje 2.8 / 3.2 kW, prurja e ajrit mesatare Vaj.nom=500 m³/h, lldhjet Gaz / Leng - Ø 12.7 mm / Ø6.35 mm, I kompletuar me te gjithë elemente e nevojshem per montim, termostat ambient, kabull komunikimi me pajisjen e jashtme si dhe te gjithë aksesoret e nevojshem.	cope	16	84,358.0	1,349,728
An. M-1.29	F. V Kondicioner VRF Tipi Mural, kapaciteti ne ftohje / ngrohje 3.6 / 4.1 kW, prurja e ajrit mesatare Vaj.nom=560 m³/h, lldhjet Gaz / Leng - Ø 12.7 mm / Ø6.35 mm, I kompletuar me te gjithë elemente e nevojshem per montim, termostat ambient, kabull komunikimi me pajisjen e jashtme si dhe te gjithë aksesoret e nevojshem.	cope	1	87,096.0	87,096
An. M-1.30	F. V Kondicioner VRF Tipi Mural, kapaciteti ne ftohje / ngrohje 4.5 / 5.0 kW, prurja e ajrit mesatare Vaj.nom=670 m³/h, lldhjet Gaz / Leng - Ø 12.7 mm / Ø6.35 mm, I kompletuar me te gjithë elemente e nevojshem per montim, termostat ambient, kabull komunikimi me pajisjen e jashtme si dhe te gjithë aksesoret e nevojshem.	cope	1	90,749.0	90,749
An. M-1.31	F. V Kondicioner VRF Tipi kanalor, kapaciteti ne ftohje / ngrohje 7.1 / 8.0 kW, prurja e ajrit mesatare Vaj.nom=1280 m³/h, lldhjet Gaz / Leng - Ø 15.88 mm / Ø6.35 mm, I kompletuar me te gjithë elemente e nevojshem per montim, termostat ambient, kabull komunikimi me pajisjen e jashtme si dhe te gjithë aksesoret e nevojshem.	cope	1	95,439.0	95,439
An. M-1.32	F. V Kondicioner VRF Tipi kanalor, kapaciteti ne ftohje / ngrohje 11.2 / 12.5 kW, prurja e ajrit mesatare Vaj.nom=1840 m³/h, lldhjet Gaz / Leng - Ø 15.88 mm / Ø6.35 mm, I kompletuar me te gjithë elemente e nevojshem per montim, termostat ambient, kabull komunikimi me pajisjen e jashtme si dhe te gjithë aksesoret e nevojshem.	cope	1	106,783.0	106,783
An. M-1.33	F. V Kondicioner VRF Tipi dysHEME, kapaciteti ne ftohje / ngrohje 2.8 / 3.2 kW, prurja e ajrit mesatare Vaj.nom=580 m³/h, lldhjet Gaz / Leng - Ø 12.7 mm / Ø6.35 mm, I kompletuar me te gjithë elemente e nevojshem per montim, termostat ambient, kabull komunikimi me pajisjen e jashtme si dhe te gjithë aksesoret e nevojshem.	cope	2	788,088.0	1,576,176

An. M-1.34	F. V Kondicioner VRF Tipi dysheme, kapaciteti ne ftohje / ngrohje 3.6 / 4.0 kW, prurja e ajrit mesatare Vaj.nom=690 m³/h, lidhjet Gaz / Leng - Ø 12.7 mm / Ø6.35 mm, 1 kompletuar me te gjithë elemente e nevojshem per montim, termostat ambienti, kabull komunikimi me pajisjen e jashtme si dhe te gjithë aksesoret e nevojshem.	cope	11	87,879.0	966,669
An. M-1.35	F. V Kondicioner VRF Tipi dysheme, kapaciteti ne ftohje / ngrohje 5.6 / 6.3 kW, prurja e ajrit mesatare Vaj.nom=1000 m³/h, lidhjet Gaz / Leng - Ø 12.7 mm / Ø6.35 mm, 1 kompletuar me te gjithë elemente e nevojshem per montim, termostat ambienti, kabull komunikimi me pajisjen e jashtme si dhe te gjithë aksesoret e nevojshem.	cope	3	90,551.0	271,653
An. M-1.36	F. V Kondicioner VRF Tipi dysheme, kapaciteti ne ftohje / ngrohje 7.1 / 8.0 kW, prurja e ajrit mesatare Vaj.nom=1200 m³/h, lidhjet Gaz / Leng - Ø 12.7 mm / Ø6.35 mm, 1 kompletuar me te gjithë elemente e nevojshem per montim, termostat ambienti, kabull komunikimi me pajisjen e jashtme si dhe te gjithë aksesoret e nevojshem.	cope	1	101,847.0	101,847
An. M-1.37	F. V KOMPRESOR I SISTEMIT "VRV" VERSION POMPE NXHTESIE - Kapaciteti termik maksimal ne Ftohje: Q = 135 kW - Kapaciteti termik maksimal ne Ngrrohje: Q = 150 kW - Kompresori model: Inverter - Lidhjet e tubove Gaz: Ø 28.58 mm - Lidhjet e tubove Leng: Ø 12.7 mm 1 kompletuar me te gjithë elemente e nevojshem per montim, termostat ambienti, kabull komunikimi me pajisjen e jashtme si dhe te gjithë aksesoret e nevojshem.	cope	1	3,351,675.0	3,351,675
An. M-1.38	F. V Perde Ajri 2 ml, mbi deren hyrese ne objekt	cope	1	38335	38335
An. M-1.39	F. V Paisje mono-split, ftohje/ngrohje 2.8 / 3.2 kW, saisa e ajrit max/min: 370/500 m³/h	cope	1	43766	43766
A 48	F. V Kanale ajri prej paneli poliuretani i veshur me shtrese alumini nga te dyja anet per aplikime ne ambiente spitalore te brendshme. Teknologjia e panelit: Piral HD Hydrotec antimikrobiale me vete-pastrim. Spesori 20.5mm, densiteti 52 kg/m³, trashesia e aluminit 80/80 mikron, shtesa e brendshme e lenuar, klasa e reagimit ndaj zjarrit 0-1 referuar dekreti ministerial italian 26/06/84 ose klasa B sipas standardit EN13501-1 te komunitetit europian.	m2	95	3918	372210

A 49	F.V Damfer per ballancimin e renies se presionit Ø 125 mm	cope	4	2291	9164
A 50	F.v grille thithje 45 grade (65 x 20) cm	cope	4	6816	27264
A 50	F.v grille thithje 45 grade (60 x 20) cm	cope	1	6816	6816
A 51	F.V. Grile per dhenie ajri , prej alumini te adronizuar me 2 rreshta me permasa 325x125 mm, per 150 m ³ /h, 7 Pa	cope	2	2375	4750
A 51	F.V. Grile per marje ajri ajri , prej alumini te adronizuar me 1 rreshta me permasa 325x125 mm, per 150 m ³ /h, 7 Pa	cope	2	2375	4750
A 52	F.v Difuzor swiril per dhenie ajri te griptezuar , 60x60 me prurje ajri 550 m ³ /h dhe ΔP=23 Pa, perfshire planiumin dhe damferin per ballancimin e ajrit	cope	4	17672	70688
A 52	F.v Difuzor swiril per dhenie ajri te griptezuar , 60x60 me prurje ajri 500 m ³ /h dhe ΔP=22 Pa, perfshire planiumin dhe damferin per ballancimin e ajrit	cope	1	17672	17672
Shuma 7		leke			12847962
SISTEMI I GAZIT MEDIKAL					
An 69	F.V Priza e kthimit te gazit anestazik	pcs	3	7450	22350
An 70	F.V Njesi kontrolli te valvoleve te karit per 3 gazet e O2.Ac,VAC	pcs	2	25631	51262
An 72	F.V Koke krevati 1 vendshe e cila pershin 3 dalje gazesh per revat O2.Ac,Vac, prize elektrike	pcs	32	23544	753408
An 74	F.V Njesi tavatore per anestazi	pcs	1	6548	6548
An 76	F.V Kuader reduktimi i shalles se dyte per 3 gaze O2.Ac,Vac, i kompletuar me kuti metalike per panelin e reduktimit te shalles se dyte, linje dopio reduktimi, dalje gazi per raste urgjente O2 NIST , dalje gazi per raste urgjente AIR NIST, kontrolli presioni 2-6 bar (LP:3,2-HP:4,8bar) XP201A , kontaktor vakumi 150mbar to -1000m	pcs	1	25631	25631
	F.V Tuba Cu 42x1.5 mm En 13350	ml	30	2,850.00	85500
2.494/e	F.V Tuba Cu 35x1.5 mm En 13351	ml	30	2,177.00	65310
2.494/d	F.V Tuba Cu 28x1 mm En 13352	ml	30	1,314.00	39420
2.494/c	F.V Tuba Cu 22x1 mm En 13353	ml	65	1,114.00	72410
2.494/b	F.V Tuba Cu 18x1 mm En 13354	ml	35	1,012.00	35420
2.494/a	F.V Tuba Cu 16x1 mm En 13355	ml	14	850.00	11900
2.494/e	F.V Tuba Cu 14x1 mm En 13356	ml	94	800.00	75200
2.494/f	F.V Tuba Cu 12x1 mm En 13357	ml	94	780.00	73320
2.494/g	F.V Tuba Cu 10x1 mm En 13358	ml	94	700.00	65800
Shuma 8		leke			1,383,479
Shuma C					15,865,153
D. PAISJE DHE MAKINERI					

	1. Impianti I mbrojtjes nga zjarri				
M-1.1	F. V Naspo zjaritime orjentim manual. Kasetë jashte murit, llamarine geliku e emaluar me ngjyrë të kuqe RAL 3000, norma 9227, me baze rezine. Dimensionet (750x700x200)mm. Valvul me sferë 1. Aksesori: saraqineske ndërprerëse 1½", lançë + zorre uji DN 25.	kompl	5	24,056.0	120,280
M-1.2	F. V Grupi i lidhjes me motopompen për hidrant DN 70. Vendosja në kasetë të jashtme, llamarine geliku të emaluar ne ngjyre, te kuqe RAL 3000, valvol sigurie dhe moskthimi 2" (DN 50) materiali i grupit bronz.	kompl	1	21,430.0	21,430
M-1.3	F. V Rezervuar zingato per furnizimin me uje, kapaciteti 3 000 lit, De=1270 mm, H=2400 mm, lidhjet 2".	cope	3	62,203.0	186,609
M-2.1	F. V POMPE E ZJARRIT - Pruija: 2x14.4 m³/h - Prevalenca: 2x40m kH2O - Fuga elektrike: 2 x 3.7 kW - Nr. i rotullimeve: 2950 rpm - Ushqimi: 3~400V/50Hz - Rryma: 2 x 7.8 A - Shkalla e mbrojtjes: IP 54 - Lidhjet: 2"	kompl	1	808,595.0	808,595
M-3.1	F. V Fikëse zjarr me pluhur, destinacioni per mbrojtjen e paisjeve ne ndertes. Tip bombel (e levizshem). Klasa e zjarrit 55A-233BC, kapaciteti normal 6 kg, pesha 17.6 kg. Diametri 190mm, lartesia 640 mm.	cope	7	13,296.0	93,072
M-3.2	F. V Fikëse zjarr me CO2, destinacioni per mbrojtjen e paisjeve elektrike ne ndertes. Tip bombel (e levizshem). Klasa e zjarrit 27A-233BC, kapaciteti normal 6 kg, pesha 11 kg. Diametri 160mm, lartesia 560 mm.	cope	1	13,347.0	13,347
	Shuma 1	leke			1,243,333
	2. Impianti I kondicionimit				

A 53	TRAJTIM AJRI AHU spesori i Struktures se ahu 50mm me veshje antibakteriale, sipas standartit te paisjeve te trajtimit te ajrit ne ambiente spitalore. se AHU t - Ventilator (variabel speed) dergim 3000 m3/h 120 (Pa) renie presioni ne tubacionet e ajrit - Ventilator (variabel speed) kthim 3000 m3/h 150 (Pa) renie presioni ne tubacionet e ajrit - Sistemi rregullimit monitorimit dhe kontrollit te centralit te trajtimit te ajrit Kembyes nxehtesie Uje-uje me kapacitet- Ngrohje 15.5 kW - 45/40 C - Ftohje 15 kW - 7/12 C modulare 3-vie per kembyesin ftohese/ngrohese - Filter H 9 - Damfera stabilizimi ajri mberthimit dhe i fiksimit Antivibrante etj.	cope	1	1531527	1531527
A 54	F.v. pompe nxehtesie e tipit ajer-uje, Pump&Tank (per ngrohje + ftohje) AHU ftohes 15.5 kW - Sistemi i komandimit dhe kontrollit - Per kapacitet nominal - kapacitet nominal ngrohës 18 kW - Sistemi i mberthimit dhe i fiksimit	cope	1	966328	966328
	Shuma 2	leke			2,497,855
	Shuma D				3,741,188
	PERMBLEDHESE				
A	A. PUNIME NDERTIMI				24764573.2
B	B. INSTALIMET ELEKTRIKE				9853944.2
C	C. INSTALIME HIDRONIKE				15,865,153
D	D. PAISJE DHE MAKINERI				3,741,188
	Totali	leke			54,224,858

Shoqeria "6D-PLAN" sh.p.k

Administrator

Ing. Saidjon Kodhelaj